



# Baliwag Water District

ISO 9001:2015 Certified

Col. Tomacruz St., Poblacion, Baliwag, Bulacan 3006

Tel. No. : (044) 766-2618 Fax No. : (044) 766-3737

www.baliwagwd.com

## BID BULLETIN NO. 2

### **Invitation to Bid for Design, Supply and Installation of 500 m<sup>3</sup> effective volume capacity with 300 mm free board Glass-Fused or Epoxy-Coated to Steel Bolted Tank (Sealant Type) with Booster Pumps and Piping Works**

This Bulletin No. 2 is being issued to inform the bidders on the following:

1. Tank diameter of 12.80 meters can be reduced at a minimum of 10.25 meters, provided that proposed size is approved by the district. Acceptable diameter is 10.25 meters to 12.80 meters.
2. If soil bearing test result will be below 2,000 psf, variation orders will be allowed.
3. On page 68, it was stated that dry film thickness shall be at 13-26 mils, while on page 78 e.2. wall coatings, it was stated that internal coating shall be at 7.1 mils. And at e.4. dry film thickness, it was stated that the required is at 120 micron minimum. As clarification, final coating requirement will be set at 320 micron.
4. On page 72, 9.1 paragraph 2, it is the Tank Manufacturer who shall issue the Five (5) Years Extended Warranty for the Tank Coating.
5. Aluminum stairs are still being required for the tank.
6. The Bids and Awards Committee, during the bid opening shall check for the correctness and completeness of all bids submitted. Then, if submitted bid requirements are correct and complete, post qualification shall take place. The BAC has no place and time for any personal concerns/issues other than the subject of bidding which is the Design, Supply and Installation of 500 m<sup>3</sup> effective volume capacity with 300 mm free board Glass-Fused or Epoxy-Coated to Steel Bolted Tank (Sealant Type) with Booster Pumps and Piping Works.
7. Freeboard measurement shall be 300 mm. But still, effective volume capacity of the tank shall be at 500 cubic meters.
8. Voltage rating requirement is at 220 to 255 volts.
9. NECC or certificate of credit line or cash deposit certificate will be acceptable as part of the financial requirement provided that stipulated amount in the submitted document is sufficient to cover the required financial requirement.
10. Foreign component will only be included in the project progress report once it was delivered to the project site.
11. The contract duration of 210 calendar days will be final.
12. Statement of on-going and similar completed projects shall be provided in two separate sheets.
13. For the copies of the bid, 1 original and 4 duplicate copies will be required.
14. Notice of Award and Notice to Proceed will all be issued this month of December 2020.
15. Bid Securing Declaration will be accepted in lieu of Bid Security.
16. On page 68-69, particularly on 4.1 and 4.2, the tank manufacturer shall provide a certificate of compliance on the given conditions/requirements as part of supporting documents.

# Baliwag Water District

17. Securing of occupancy and building permit shall be the responsibility of the winning bidder.
18. Electromechanical component shall have one (1) VFD and one (1) soft starter. There will be no PLC requirement.

For information and guidance of all concerned:

By:

  
**ROBERTO G. ESTRELLA**  
BAC Chairman

- being issued to inform the bidders on the following:
1. Diameter of 12.50 meters can be reduced at a minimum of 10.25 meters, provided that proposed size is approved by the district. Acceptable diameter is 10.25 meters to 12.50 meters.
  2. If soil bearing test result will be below 2,000 psf, variation orders will be allowed.
  3. On page 68, it was stated that dry film thickness shall be at 13.25 mils, while on page 76 & 77, wall coatings, it was stated that internal coating shall be at 7.1 mils and at 2.4, dry film thickness, it was stated that the required is at 220 micron thickness. As clarification, final coating requirement will be set at 320 micron.
  4. On page 72, 9.1 paragraph 2, it is the Tank Manufacturer who shall issue the five (5) Years Extended Warranty for the Tank Coating.
  5. Aluminum stairs are still being required for the tank.
  6. The Bids and Awards Committee, during the bid opening shall check for the correctness and completeness of all bids submitted. Then, if submitted bid requirements are correct and complete, post qualification shall take place. The BAC has no place and time for any personal concerns/issues other than the subject of bidding which is the Design, Supply and Installation of 500 m<sup>3</sup> effective volume capacity with 300 mm free board Glass-Fused or Epoxy-Coated to Steel Bolted Tank (Sediment Type) with Booster Pump and Piping Works.
  7. Freeboard measurement shall be 300 mm. But still, effective volume capacity of the tank shall be at 500 cubic meters.
  8. Voltage rating requirement is at 220 to 255 volts.
  9. Letter of certificate of credit line or cash deposit certificate will be acceptable as part of the financial requirement provided that stipulated amount in the submitted document is sufficient to cover the required financial requirement.
  10. Foreign component will only be included in the project progress report once it was delivered to the project site.
  11. The contract duration of 310 calendar days will be final.
  12. Statement of on-going and similar completed projects shall be provided in two separate sheets.
  13. For the copies of the bid, 1 original and 4 duplicate copies will be required.
  14. Notice of Award and Notice to Proceed will all be issued this month of December 2020.
  15. Bid Securing Declaration will be accepted in lieu of Bid Security.
  16. On page 68-69, particularly on 4.1 and 4.2, the tank manufacturer shall provide a certificate of compliance on the given conditions/requirements as part of supporting documents.